



## Coal Fired Stove Draft Measurement Location

The following test can be performed with the A797 draft probe and a TPI manometer or combustion analyzer with manometer capability.

Refer to the manometer or analyzer instruction manual for specific instructions on the steps required for setting up the test instrument prior to performing this test.

**Once the stove is at operating temperature, insert the A797 draft probe into the flue pipe to measure draft.**

